

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 514

Dated: 16/08/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Indian Institute of Health Management Research Located at Plot No. 03, Pkt HAF, Sector - 18A, Dwarka, New Delhi, comprised of Basement, Ground+3 UFs was issued Fire Safety Certificate vide letter No. F6/DFS/DFS/MS/2008/1236, dated 30/04/2008. The premises was re inspected by the officer concerned of this department on 02/08/2024 in the presence of Sh. Sujaram (manager) All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with NBC/BBL/DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 16/08/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/08/2024..... at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. The Manager , Indian Institute of Health Management Research Located at Plot No. 03, Pkt HAF, Sector - 18A, Dwarka, New Delhi
2. Directorate of Education Old Secretariat Delhi - 110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building: Indian Institute of Health Management Research Located at Plot No. 03, Pkt HAF, Sector – 18A, Dwarka, New Delhi.
2. Type of Occupancy : Educational (Basement +Ground+ 3 UFs)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2008/1236, dated 30/04/2008
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2007/622, dated 02/03/07
6. Date of inspection : 02/08/2024
7. Name of the Inspecting Officer : ADO/DWK
8. Name and designation of Officer  
from the building side: Sh. Sujaram ( Manager)
9. Year of Construction : before 2008
10. Applicant's letter No. : Email dated 01/07/2024

| S No | Minimum standards on fire prevention and fire safety U/R 33 | As per NBC           | Provided at site    | Remarks MR/NMR     |
|------|-------------------------------------------------------------|----------------------|---------------------|--------------------|
| 1.   | Access of building                                          |                      |                     |                    |
|      | • Road width                                                | 06 mtr               | Provided            | MR                 |
|      | • Gate width                                                | 5 mtr                | Provided            | MR                 |
|      | • Width of internal road                                    | NA                   | NA                  | NA                 |
| 2.   | Number, width, Type & Arrangements of exits                 |                      |                     |                    |
|      | a. Number of staircases                                     | 03 Nos.              | Provided            | MR                 |
|      | • Upper floors                                              | 03 Nos. ramp         | Provided            | MR                 |
|      | • Basements                                                 |                      |                     |                    |
|      | b. Width of staircases                                      | 1.5 m                | 1.48m,1.46m & 1.42m | MR(Being old case) |
|      | • Upper floors                                              | 1.5 m                | 1.48m,1.46m & 1.42m | MR(Being old case) |
|      | • Basements                                                 |                      |                     |                    |
|      | c. Protection of exits                                      |                      |                     |                    |
|      | • Fire check door                                           | Required in basement | Provided            | MR                 |
|      | • Pressurization                                            | NA                   | NA                  | NA                 |
|      | d. No of continuous staircase to terrace                    | Required             | Provided            | MR                 |
|      | e. Width Of Corridor                                        | Required             | 150cm               | MR                 |
|      | f. Door Size                                                | 01 mtr               | Provided            | MR                 |
| 3.   | Compartmentation                                            |                      |                     |                    |
|      | • Fire check door                                           | Required in basement | Provided            | MR                 |
|      | • Sealing of electrical shafts                              | NA                   | NA                  | NA                 |
|      | • Fire Rating of shaft door                                 | NA                   | NA                  | NA                 |
|      | • Water Curtain                                             | NA                   | NA                  | NA                 |
|      | • Fire Dampers                                              | NA                   | NA                  | NA                 |



|     |                                              |                                                               |                       |          |    |
|-----|----------------------------------------------|---------------------------------------------------------------|-----------------------|----------|----|
| 4.  | Smoke managements System                     |                                                               |                       |          |    |
|     | • Basements                                  | 30 a/c charge                                                 | Provided              |          | MR |
|     | • Upper floors                               | 12 a/c charge                                                 | Natural ventilation   |          | MR |
| 5.  | Fire Extinguishers                           |                                                               |                       |          |    |
|     | • Total numbers                              | 01 no. for every 300 sq.mtr ABC or CO <sub>2</sub> ISI marked | Provided              | MR       |    |
|     | • Types                                      |                                                               | ABC & CO <sub>2</sub> | MR       |    |
|     | • IS marking                                 |                                                               | ISI marked            | MR       |    |
| 6.  | First – Aid Hose Reels                       |                                                               |                       |          |    |
|     | • Total numbers on each floor                |                                                               | 02 Nos.               | Provided | MR |
|     | • Length of hose reel hose                   |                                                               | 30 mtr                | Provided | MR |
|     | • Nozzle diameter                            |                                                               | 05 mm                 | Provided | MR |
| 7.  | Automatic fire detection and alarming system |                                                               |                       |          |    |
|     | • Type of detectors                          | Required                                                      | Provided              | MR       |    |
|     | • Location of Main Panel                     | NA                                                            | NA                    | NA       |    |
|     | • Location of Repeater Panel                 | NA                                                            | NA                    | NA       |    |
|     | • Alternate source of power                  | NA                                                            | NA                    | NA       |    |
|     | • Hooters' Location                          | NA                                                            | NA                    | NA       |    |
| 8.  | MOEFA                                        |                                                               | NA                    | NA       | NA |
| 9.  | Public Address System                        |                                                               | Required              | Provided | MR |
| 10. | Automatic Sprinkler System                   |                                                               |                       |          |    |
|     | • Basements                                  | Required                                                      | Provided              | MR       |    |
|     | • Upper Floor                                | NA                                                            | NA                    | NA       |    |
|     | • Sprinkler above false ceiling              | NA                                                            | NA                    | NA       |    |
| 11. | Internal Hydrants:                           |                                                               |                       |          |    |
|     | • Size of riser/down- comer                  | 100 mm                                                        | Provided              | MR       |    |
|     | • Number of hydrants per floor               | 02 Nos.                                                       | 03 Nos.               | MR       |    |
|     | • Hose Box                                   | Required                                                      | Provided              | MR       |    |
| 12. | Yard Hydrants                                |                                                               |                       |          |    |
|     | • Total number of hydrants                   | NA                                                            | NA                    | NA       |    |
|     | • Hose Box                                   | NA                                                            | NA                    | NA       |    |
| 13. | Pumping Arrangements:                        |                                                               |                       |          |    |
|     | • Ground Level                               | 2280 lpm                                                      | Provided              | MR       |    |
|     | • Discharge of main pump                     | 70 m                                                          | Provided              | MR       |    |
|     | ➤ Head of main pump                          | 1                                                             | Provided              | MR       |    |
|     | ➤ Number of main pumps                       | 180 lpm                                                       | Provided              | MR       |    |
|     | ➤ Jockey pump out put                        | 70 m                                                          | Provided              | MR       |    |
|     | ➤ Jockey pump head                           | 2280 lpm                                                      | Provided              | MR       |    |
|     | ➤ Standby Pump out put                       | 70 m                                                          | Provided              | MR       |    |
|     | ➤ Standby Pump Head                          | Required                                                      | Provided              | MR       |    |
|     | ➤ Auto staring/Manual stopping               | Required                                                      | Provided              | MR       |    |
|     | ➤ Pump House Access                          |                                                               |                       |          |    |
|     | • Terrace level                              | 900 lpm                                                       | Provided              | MR       |    |
|     | ➤ Discharge of pump                          | 40 mtr                                                        | Provided              | MR       |    |
|     | ➤ Head of the pump                           | Required                                                      | Provided              | MR       |    |
|     | ➤ Power supply                               | Required                                                      | Provided              | MR       |    |
|     | ➤ Auto starting of pump                      |                                                               |                       |          |    |

2


be




2/10

|     |                                                                          |             |                                                           |    |
|-----|--------------------------------------------------------------------------|-------------|-----------------------------------------------------------|----|
| 14. | Captive water Storage for fire fighting:                                 |             |                                                           |    |
|     | • Under ground tank capacity                                             | 50,000 ltrs | Provided                                                  | MR |
|     | ➤ Draw off connection                                                    | NA          | NA                                                        | NA |
|     | ➤ Fire service inlet                                                     | NA          | NA                                                        | NA |
|     | ➤ Access to tank                                                         | NA          | NA                                                        | NA |
|     | • Overhead Tank capacity                                                 | 10,000 ltr  | Provided                                                  | MR |
| 15  | Exit Signage                                                             | Required    | Provided                                                  | MR |
| 16. | Provision of Lifts                                                       |             |                                                           |    |
|     | ➤ Pressurization of Lift Shaft                                           | NA          | NA                                                        | NA |
|     | ➤ Pressurization of lift lobby                                           | NA          | NA                                                        | NA |
|     | ➤ Communication in lift Car                                              | Required    | Provided                                                  | MR |
|     | ➤ Fireman's Grounding Switch                                             | Required    | Provided                                                  | MR |
|     | ➤ Lift Signage                                                           | Required    | Provided                                                  | MR |
| 17. | Standby power supply                                                     | Required    | Provided                                                  | MR |
| 18. | Refuge Area                                                              |             |                                                           |    |
|     | ➤ Total area                                                             | NA          | NA                                                        | NA |
|     | ➤ Location                                                               | NA          | NA                                                        | NA |
| 19. | Fire control room                                                        |             |                                                           |    |
|     | ➤ Detector system panel                                                  | NA          | NA                                                        | NA |
|     | ➤ Flow Switch Panel                                                      | NA          | NA                                                        | NA |
|     | ➤ PA System Panel                                                        | NA          | NA                                                        | NA |
|     | ➤ Battery backup                                                         | NA          | NA                                                        | NA |
|     | ➤ Building Floor Plans                                                   | NA          | NA                                                        | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | Required    | CO2 & ABC, Fire extinguisher provided near electric panel | MR |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/2008/1236, dated 30/04/2008 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended

  
 Signature of the Inspecting Officer  
 Name: Udai Vir Singh  
 Designation: ADO/DWK

  
 D/Su  
  
 CFO(S2)  
  
 Director  
  
 5/8/24  
  
 11/8/24  
  
 6/10/24

  
 Anurag